

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Dated: 20.7.24

No. 2751

It is certified that an inspection team headed by DHERENDER G.V.A. (AE)

(Name of Officers with designation) from G.V.A.; BELKHARWATH DHAM, PHED
PBH

inspected the SPRING DALES ACADEMY, VILL. PATAWAN POST, KANPA, PBH

(Name & Address of the school) on 20/7/24 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. UPJN(R)/PBH/BL/2751 dated 10/7/24

of DLWAL UP. JAL NIGAM, PRATAPGARH (PHED Lab) certified that

the SPRING DALES ACADEMY (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 2 YEARS

Signature with Seal: 

Name : Dherender

Designation : G.V.A. (AE)

Name & Address of the Office / Department :

सहायक विकास अधिकारी (प)
वि०ख०-वादा बलखरनाथ धाम प्रतापगढ़

To
SPRING DALES ACADEMY,
VILL. PATAWAN, POST KANPA, PATTI PRATAPGARH
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Test Report



District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural)
Pratapgarh

Address- Office of executive engineer, khand karyalaya, U.P Jal Nigam (Rural), near c.m.o residence
Katra road, civil line , Pratapgarh - 230001

Report No	UPJN(R)/PBH/DL/2751	Issue Date:	10-07-2024		
Remark				Page No	1/1
Contact Person:	Digvijay Singh	Address:	UPJN Pratapgarh	Mob:	9169048466

Customer Details

Office Name and Address	Spring Dales Academy, village- Patawan, ,post-kanpa,patti ,Pratapgarh
Ref Letter No & Date	-

Basic details of sample

District	Pratapgarh	Block	Baba belkarnath dham
Gram Panchayat	-	Village	Patawan
Habitation	-	Location	Spring Dales Academy campus
Water Source	submersible pump	Sample No.	2751
Quantity of Sample	1 ltr.	Date of Collection	28-06-2024
Receiving Date	28-06-2024	S. Collector	Suraj
Sample Depositor	Avneesh jaiswal	Sampling Method	As per IS 17614: Part 1 : 2021
Analysis Start Date	29-06-2024	Analysis Completion Date:	29-06-2024

Technical Data of Analysis

1	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
2	3	4	5	6	
1	pH	7.16	6.5-8.5	6.5-8.5	IS 3025 (Part 11):2022 (Electrometric method)
2	Turbidity NTU	0.72	1	5	IS 3025 (Part 10):2023
3	TDS mg/L	416	500	2000	IS 3025 (Part 16):2023
4	Fluoride mg/L	0.196	1	1.5	IS 3025 (Part 60):2008
5	Total Hardness mg/L	246	200	600	IS 3025 (Part 21):2019
6	Total Alkalinity mg/L	272	200	600	IS 3025 (Part 23):2023
7	Chloride mg/L	115	250	1000	IS 3025 (Part 32):2019
8	Iron mg/L	0.13	1	No relaxation	IS 3025 (Part 53):2003
9	Nitrate mg/L	3.10	45	No relaxation	APHA 4500-No3UV Screening method 2017
10	Sulphate mg/L	7.94	200	400	IS 3025 (Part 24):1986

Note
1. This Certificate refers only to the particular sample(s) submitted for testing.

2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.

3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.

4. Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests reports.

Analysed By-
Deputy Technical Manager

Authorized Signatory

